



NOTES:

1. FOR DETAILS ON COMBINATION CONCRETE CURB AND GUTTER TYPES 'A', 'B' AND 'C' SEE STANDARD NO. MD-620.02 FOR SIDEWALK EXPANSION JOINTS SEE STANDARD NO. MD-655.01.
2. WHEN AN EXISTING ENTRANCE IS LESS THAN 20 FEET IN WIDTH A UNIFORM TAPER SHALL BE CONSTRUCTED TO TIE INTO THE EXISTING ENTRANCE AS DIRECTED BY THE ENGINEER.
3. REFER TO STANDARD NO. MD-630.02 FOR CURRENT VERSION.
4. REFER TO 11.0 FOR ENTRANCE DESIGN STANDARDS.

DEPRESSED CURB ENTRANCE ENGINEERING ACCESS PERMITS

